



**Cable ID: P8-O40-1/1M-1**


Date / Time: 01/06/2015 01:30:36 PM  
**Headroom 2.9 dB (NEXT 12-45)**  
**Test Limit: TIA Patch Cord Cat6 1.0m**  
 Cable Type: Cat 6 UTP  
 Calibration Date: 03/26/2013

Operator: Your Name  
 Software Version: 2.7400  
 Limits Version: 1.9300  
 NVP: 69.0%


**Test Summary: PASS**

Model: DTX-1800  
 Main S/N: 8943015  
 Remote S/N: 8943016  
 Main Adapter: DTX-PCU6M  
 Remote Adapter: DTX-PCU6R

Length (ft)	[Pair 12]	3
Prop. Delay (ns)	[Pair 45]	6
Delay Skew (ns)	[Pair 45]	1
Resistance (ohms)	[Pair 36]	0.5



Wire Map (T568B)  
**PASS**



Worst Case Margin Worst Case Value

<b>PASS</b>	MAIN	SR	MAIN	SR
Worst Pair	12-45	36-45		
<b>NEXT (dB)</b>	2.9	2.9		
Freq. (MHz)	246.0	250.0		
Limit (dB)	39.4	39.2		

<b>PASS</b>	MAIN	SR	MAIN	SR
Worst Pair	12	12		
<b>RL (dB)</b>	4.5	4.5		
Freq. (MHz)	195.5	199.0		
Limit (dB)	15.1	15.0		

